



HOWE SPRINGS FIRE DISTRICT
DIVISION OF FIRE AND LIFE SAFETY

Fire Prevention Information for Contractors

The following needs to be addressed and verified in the field prior to a C/O being issued for all new construction in the Howe Springs Fire District.

1. Exit signs on all exit doors. 2006 IBC 1011
2. Emergency lighting of the means of egress. 2006 IBC 1006
3. Locks cannot require the use of a key and single action to be opened from the egress side. 2006 IFC 1008.1.8
4. Fire extinguishers in accordance with this section and NFPA 10. 2006 IFC 906.2
5. A letter stating that all paved areas will support a minimum of 75,000 lbs. 2006 IFC Appendix D 102.1
6. A Knox box keyed to Howe Springs Fire District 2006 IFC 506.1
7. All new fire hydrants in Howe Springs District shall be equipped with a "storz" type connection on the 4/5 inch discharge.

Also proper permitting and inspections through [Florence County Planning](#)